



PROVIDE A MINIMUM OF 7 PIPE DIAMETERS OF STRAIGHT PIPE TO PUMP INLET.
ALTERNATELY, PROVIDE SUCTION DIFFUSER IN PLACE OF STRAINER.

SCALE: NONE