



NOTES:

1. DURING WINTER SET-UP, COIL IS DRAINED AND AIR IS CIRCULATED THRU COIL VIA DUCTS, USING AIR HANDLER FAN.
2. COIL DRYING CONNECTIONS TO HAVE SCREW CAPS. CONNECTOR PIPE SAME SIZE AS CHILLED WATER PIPE OR 2" MINIMUM, 4" MAXIMUM.
3. PROVIDE DRAINS AT ALL LOW POINTS IN PIPING NETWORK. PROVIDE MANUAL AIR VENTS AT ALL HIGH POINTS IN PIPING NETWORK.